

STOP CORONA : Wash your Hands, Wear Mask, Maintain Social Distancing

	<p>DELHI JAL BOARD: GOVT. OF NCT OF DELHI OFFICE OF DIRECTOR (A & P) VARUNALAYA PHASE-II KAROL BAGH, NEW DELHI-110005 PHONE:- 011-23544794 E-mail:- djbdirector@gmail.com</p>	
---	---	---

No. G-4(vi)/DJB/Dir.(A&P)/2021/04

Dated : 28/07/2021

To

Shri Neeraj Aggarwal,
Dy. Secretary, (Question Branch),
Delhi Vidhan Sabha Secretariat,
Old Secretariat, Delhi – 110054.

**Subject:- Vidhan Sabha Starred Question No. 39 due for 30.07.2021 asked
by Shri Naresh Yadav, MLA.**

Sir,

Please refer to your letter No. F-11(B-1)/VI/2015-20/VSS/Ques.Branch/6046 dated 22.07.2021 on the above quoted subject.

In this connection I am enclosing herewith the reply of the aforementioned Vidhan Sabha Question in so far as the Delhi Jal Board is concerned.

This issues with the approval of the competent authority.

Encl: As above.


(Bansh Raj)
Director (Admn.& Personnel)

निदेशक (प्रशासन एवं कार्मिक)
Director (A&P)
दिल्ली जल बोर्ड
Delhi Jal Board

विभाग का नाम :- दिल्ली जल बोर्ड

विभाग का पता :- निदेशक (प्रशासनिक एवं कार्मिक)
करोल बाग, नई दिल्ली


तारांकित प्रश्न संख्या :- 39

दिनांक :- 30.07.2021


प्रश्नकर्ता का नाम :- श्री नरेश यादव, विधायक

क्या माननीय जल मंत्री यह बताने की कृपा करेंगे कि :

अ.क्र.	प्रश्न	उत्तर
(क)	क्या यह सत्य है कि महरौली विधानसभा क्षेत्र जल आपूर्ति में अत्यंत कमी का सामना कर रहा है और एमवीवी परियोजना के जल्दी पूरे होने के कोई आसार नहीं हैं;	जी हाँ। यह निवेदित किया जाता है कि महरौली निर्वाचन क्षेत्र की जनसंख्या 3.5 लाख है और पानी की उपलब्धता 15 एमजीडी पानी की मांग के मुकाबले लगभग 10 एमजीडी है। स्रोत पर पानी की कम उपलब्धता के कारण महरौली टाउनशिप को पानी की कमी की समस्या का सामना करना पड़ता है जो गर्मी के मौसम में मांग बढ़ने के कारण और बढ़ जाता है। जहां तक एमवीवी परियोजना का संबंध है, वर्तमान में लगभग 80% कार्य पूरे हो चुके हैं और शेष 31.03.2022 तक पूरा होने की संभावना है।
(ख)	क्या यह सत्य है कि किशनगढ़ भूमिगत जलाशय, जिसका उद्घाटन माननीय मुख्यमंत्री ने 25.12.2019 को किया था, अभी तक चालू नहीं हुआ है;	नए किशनगढ़ यूजीआर (1.80 एमएल क्षमता) का उद्घाटन माननीय मुख्यमंत्री द्वारा दिनांक 25.12.2019 को नए यूजीआर-पंप हाउस को पुराने नेटवर्क से जोड़कर किया गया था। चूंकि, किशनगढ़ में नए यूजीआर सह बीपीएस में अधिक डिस्चार्ज वाले उच्च हेड के पंप हैं; इसके संचालन के परिणामस्वरूप पानी की आपूर्ति की अवधि में कमी आई है, इसलिए नए यूजीआर को चालू करने के लिए अधिक पानी की मांग है। चूंकि किशनगढ़ पुराने यूजीआर (0.6 एमएल क्षमता) में प्राप्त थोक आपूर्ति 7.2 एमएल की मांग के मुकाबले काफी कम लगभग 1.7-2 एमएल है, नए पंपों के साथ स्थायी आपूर्ति को बनाए नहीं रखा जा सकता है। इसलिए नए यूजीआर-पंपों का संचालन बंद कर दिया गया है। आसपास के नलकूपों की बोरिंग/री-बोरिंग द्वारा किशनगढ़ यूजीआर की जलापूर्ति बढ़ाने का प्रस्ताव है। और यह यूजीआर अब 30.11.2021 तक चालू होने की संभावना है।
(ग)	ये परियोजनाएँ कब तक पूरी हो जाएँगी;	मेसर्स एमवीवी परियोजना का कार्य 31.03.2022 तक सड़क स्वामित्व एजेंसियों जैसे कि एसडीएमसी से आवश्यक अनुमति की उपलब्धता पर पूरा होने की संभावना है।


निदेशक (प्रशासन एवं कार्मिक)
Director (A&P)
दिल्ली जल बोर्ड
Delhi Jal Board

(घ)	यदि मौजूदा ठेकेदार इस कार्य को करने में सफल नहीं होता है तो क्या सरकार के पास इस परियोजना को पूरा करवाने का कोई वैकल्पिक प्रस्ताव है; और	एमवीवी परियोजना पूर्णता के अंतिम चरण में है और वर्तमान एजेंसी यानी मेसर्स एमवीवी ने इसे 31.03.2022 तक पूरा करने का कार्यक्रम दिया है। वर्तमान ठेकेदार के शेष कार्य को पूरा करने में विफल रहने की स्थिति में, अनुबंध के अनुसार आवश्यक कदम उठाये जायेंगे।
(ङ)	क्या यह संभव है कि इस परियोजना के पूरे हो चुके भाग को किसी निजी भागीदार को परिचालन हेतु सौंप दिया जाए, ताकि जल आपूर्ति में कमी का बेहतर प्रबंधन किया जा सके और दिल्ली जल बोर्ड के स्टाफ का कार्यभार भी कम किया जा सके?	परियोजना के पूर्ण भाग को संचालन के लिए मेसर्स एमवीवी को सौंपने के तौर-तरीकों पर अनुबंध समझौते के प्रावधान के अनुसार काम किया जा रहा है।


निदेशक (प्रशासन एवं कार्मिक)

निदेशक (प्रशासन एवं कार्मिक)
Director (A&P)
दिल्ली जल बोर्ड
Delhi Jal Board

Supplementary Information:-

Project work of "Improvement in service level for water supply in Mehrauli Project area and Vasant Vihar Project has been awarded to M/s MVV Water Utility Pvt. Ltd." at a total cost of 201 Cr. which has subsequently been revised to 165 Cr. The scope of work includes part of Mehrauli Constituency also. The date of start of work is 27.09.2012 with execution period of 2 years. The O&M period of Mehrauli area will start after completion of capital works.

Scope of work includes construction and renovation of 4 nos. BPS and UGR namely Qutub, Kishangarh, Bawaji and Lal Tanki. Presently, Qutub UGR, Phase -I & II have been completed and commissioned. Construction of Qutub UGR Phase-III of capacity 3.95 ML is yet to start. The new Kishangarh UGR (1.8 ML capacity) has been completed but could not be commissioned due to non availability of sufficient water. The Bawaji UGR has been completed except for a few minor works. Lal Tanki BPS has been completed. As such, 80% work at Mehrauli has been completed.

The work got delayed due to various reasons i.e delay in getting road cutting permissions from road owning agencies, deferment of work for approx. 3 years to allow deep sewer works prior to water line works at Mehrauli, delayed availability of land for construction of UGR at Kishangarh, slow progress of the work by agency and stoppage of works by NGT / Pollution Control Departments, lockdown on account of COVID-19 etc. M/s. MVV project work is now likely to complete by 31.03.22.



VIRENDER KUMAR
Chief Engineer (W) Project-I