


	DELHI JAL BOARD: GOVT. OF NCT OF DELHI OFFICE OF DIRECTOR (A & P)/Parliament Cell VARUNALAYA PHASE-II KAROL BAGH, NEW DELHI-110005 PHONE:- 011-23544794 E-mail:- djbdirector@gmail.com .	
---	---	---

DJB/Director (A&P)/VSQ-W-2023/ **Unst.-151/CM-10**

Dated: **15.12.2023**

To

Shri Neeraj Aggarwal,
Dy. Secretary, (Question Branch),
Delhi Vidhan Sabha Secretariat,
NCT of Delhi, Old Secretariat, Delhi – 110054.

Subject:-Vidhan Sabha Un-starred Question No. 151 raised by Hon'ble MLA Sh. Shiv Charan Goyal for 18.12.2023.

Sir,

Please refer to your letter No. F-11(B-1)/VII/2020-25/VSS/Ques. Branch/6312 date 07.12.2023 on the above quoted subject.

In this connection I am enclosing herewith the reply of the aforementioned Vidhan Sabha Question in so far as the Delhi Jal Board is concerned.

This issues with the approval of the competent authority.

Encl: As above.

Cheshta
Director (Admn.& Personnel)

Cheshta Yadav, IAS

निदेशक (प्रशा. एवं कार्मिक)

Director (Admn. & Personnel)

दिल्ली जल बोर्ड, दिल्ली सरकार

Delhi Jal Board, Govt. of NCT of Delhi

DJB/Director (A&P)/VSQ-W-2023/ **Unst.-151/CM-10**

Copy to:

1. Secretary to Minister of Water, Govt. of NCT of Delhi, Delhi Secretariat, I.P. Estate, New Delhi – 110002.
2. CEO, Delhi Jal Board.
3. Member (A), Delhi Jal Board.
4. Member (DR.), DJB
5. Director, Directorate of Information & Publicity, Block No. IX, Old Secretariat
6. Office Copy.

Cheshta
Director (Admn.& Personnel)

Cheshta Yadav, IAS

निदेशक (प्रशा. एवं कार्मिक)

Director (Admn. & Personnel)

दिल्ली जल बोर्ड, दिल्ली सरकार

Delhi Jal Board, Govt. of NCT of Delhi

विभाग का नाम :- दिल्ली जल बोर्ड
विभाग का पता :- निदेशक (प्रशासनिक एवं कार्मिक)
करोल बाग, नई दिल्ली

अतारांकित प्रश्न संख्या :- 151
दिनांक :- 18.12.2023
प्रश्नकर्ता का नाम :- श्री शिव चरण गोयल, विधायक
क्या माननीय जल मंत्री यह बताने की कृपा करेंगे कि :

अ.क्र.	प्रश्न	उत्तर
(क)	मोती नगर विधान सभा में करमपुरा, न्यू मोती नगर, मोती नगर, रमेश नगर, कीर्ति नगर, नामधारी कॉलोनी, मानसरोवर गार्डन, शारदा पूरी व सरस्वती गार्डन इन सभी जगहों की सीवरेज वाटर मेन ट्रंक सीवर लाइन जो कि केशवपुर एसटीपी में जाती है। क्या यह मेन ट्रंक सीवर लाइन शादीपुर से राजा गार्डन चौक तक 92 प्रतिशत सिल्ट से भरी है और बंद है;	इस मेन ट्रंक सीवर लाइन में फन सिनेमा मोतीनगर से केशोपुर एसटीपी तक सिल्ट के आंकलन का कार्य प्रगति पर है, और अनुमानतः यह कार्य 30.12.2023 तक पूरा हो जायेगा जिसके बाद इस सीवर लाइन में सिल्ट की मात्रा की जानकारी उपलब्ध हो पायेगी।
(ख)	क्या यह सत्य है कि मोती नगर विधान सभा के अधिकांश सीवर लाइन ओवरफ्लो चल रही है;	नहीं, यह सत्य नहीं है। वेस्ट दिल्ली ट्रंक सीवर के सरचार्ज रहने के कारण केवल सतगुरु राम सिंह मार्ग पर सुबह के समय ओवरफ्लो हो जाता है।
(ग)	यदि हाँ, तो इसकी सफाई की आगे की क्या योजना है, विस्तृत ब्यौरा दें; और	(ग) एवं (घ):- फन सिनेमा मोतीनगर से केशोपुर एसटीपी तक वेस्ट दिल्ली ट्रंक सीवर लाइन की सफाई का कार्य अवॉर्ड होने के बाद 6 महीनों में पूरा करने का प्रावधान है।
(घ)	मेन ट्रंक सीवर लाइन कब तक डिसिल्ट हो जाएगी, इसके एक्शन प्लान का पूरा ब्यौरा दें?	

निदेशक (प्रशासन एवं कार्मिक)

Cheshta Yadav, IAS

निदेशक (प्रशा. एवं कार्मिक)
Director (Admn. & Personnel)

दिल्ली जल बोर्ड, दिल्ली सरकार
Delhi Jal Board, Govt. of NCT of Delhi